



REPUBLIC OF KENYA
COUNTY GOVERNMENT OF NYANDARUA
DEPARTMENT OF TRANSPORT, ENERGY & PUBLIC WORKS
www.nyandarua.go.ke



PO BOX 701-20303

Telephone: 0202660859

Email: info@nyandarua.go.ke

9th May 2018

ADDENDUM TO TENDER NO. NYA/CG/PT/SSL/001/17-18

Under clause 2.5.1- Clarification of documents, the following addendum is issued to all bidders.

1. Schedule of unit rates page 42 does not apply to the bid as this is a general specification.
2. **Schedule No.1- Bill of Quantities.**

In view of part 2- technical specification section 2.12, the specifications of the bill of quantities are amended as follows;

- i) Item 1: 2 No. range 110- 130W polycrystalline solar panel or 1 No. 200- 220W range monocrystalline panel as described in the specification.
- ii) Item 3: 1 No. 180- 220AH battery for monocrystalline panel or 2 No. batteries 100-150AH for polycrystalline panel.
- iii) Item 6 and 8 should come as 1 (one) assembly.

PHILIP KINGORI

DIRECTOR- SUPPLY CHAIN MANAGEMENT SERVICES